



Sassuolo (MO), November, 12th 2024

To whom it may concerns

SUBJECT: *Compliance to the VOC French Regulation (according to French Decret No. 2011-321 of 23.03.2011).*

According to the results of test carried out at our Laboratories, we confirm that the following product:

Ultralit PU-40

Has been demonstrated to be compliant to the Class A+ emission limits as required by the VOC French Regulation.

| Chemical | Emission Limit ($\mu\text{g}/\text{m}^3$) |
|------------------------|--|
| TVOC | 1000 |
| Styrene | 250 |
| 2-Butoxyethanol | 1000 |
| Ethylbenzene | 750 |
| 1,4-Dichlorobenzene | 60 |
| 1,2,4-Trimethylbenzene | 1000 |
| Xylene | 200 |
| Tetrachloroethylene | 250 |
| Toluene | 300 |
| Acetaldehyde | 200 |
| Formaldehyde | 10 |

The above mentioned test has been carried out according to the CEN/TS 16516 standard (as a “joints” emission scenario, in conformity with the Annex I of the Decret No. 2011-321 of 23.03.2011)

Best regards.

Ultralit



www.ultralit.eu

ULTRALIT ul. Parowcowa 4C, 02-445 Warszawa, Polska
+48 50 240 75 00, info@ultralit.eu